cabur CONNECTING ENERGY SINCE 1952

QBLOK4124







QBLOK4P125A7 4-poles terminal block 125A with 7 holes

Series	QBLOK
Code	QBLOK4124
Type	QBLOK4P125A7
HS code	85369010
Colour	Grey
TECHNICAL FEATURES	
Function/Type	Distribution terminal board
Number and rated cross connection	Values for each bar
A	2 x 35 mm²
B	5 x 6 mm²
C	
D	–
Input A	2 x 35 mm²
Rated cross-section	35 mm²
Connecting capacity (flexible)	10-35 mm²
Connecting capacity (rigid)	10-35 mm²
Connecting capacity (with ferrule)	25 mm² – WP 250/29
Supply bar dimension	–
Output B	5 x 6 mm²
Rated cross-section	6 mm²
Connecting capacity (flexible)	2.5–6 mm²
Connecting capacity (rigid)	2.5–6 mm²
Connecting capacity (with ferrule)	4 mm² – WP 40/16
Output C	
Rated cross-section	–
Connecting capacity (flexible)	–
Connecting capacity (rigid)	–
Connecting capacity (with ferrule)	–
Output D	
Rated cross-section	–
Connecting capacity (flexible)	–
Connecting capacity (rigid)	–
Connecting capacity (with ferrule)	–
Electrical characteristics according to IEC EN standard	
Maximum voltage AC/DC	500 V
Maximum current (rated cross-section)	125 A
Caliber	–
Electrical characteristics according to UL Standard	
Maximum voltage AC/DC	–
Maximum current (rated cross-section)	–
Section (min-max)	–
Tightening torque value (UL)	–
Short term current allowed (Icw) (value effective for 1s)	6 kA
Peak current (Ipk)	20 kA
Rated impulse withstand voltage / pollution degree	8kV / 3
Insulation stripping length	13 mm
Tightening torque value (nom. / max.)	2 / 2.5 Nm
Plastic material	Polyamide, polycarbonate
Widht (pitch)	72 mm
Length	97 mm
Height mounted on TH35-7.5/TH35-15	52 / 59 mm
Height for panel mounting	51 mm
ACCESSORIES	
Marking	
Single marking tag	CNU/8/51 (cod. NU0851S)
Marking tag	–
End bracket	
TH35 screw type	BT/3 (cod. BT003)
TH35 snap-fit type	BTO (cod. BT007)
TH35 and G32 snap-fit type	BTU (cod. BT005)
Mounting rail	
DIN rail according to IEC 60715/TH35	–
IEC 60715/TH35	PR/3/...
APPROVALS AND MARKINGS	

Copyright © Cabur srl Sede legale Località isola Grande, 45 – 17041 Altare (SV) – Italia – Tel. 019-589991 – Fax 019-58999233 – E-mail: info@cabur.it

cabur CONNECTING ENERGY SINCE 1952

QBLOK4124

DESCRIZIONE DEL PRODOTTO

QBLOK4P125A7 4-poles terminal block 125A with 7 holes

Copyright © Cabur srl Sede legale Località isola Grande, 45 – 17041 Altare (SV) – Italia – Tel. 019-589991 – Fax 019-58999233 – E-mail: info@cabur.it

calpe INDUSTRIAL MARINE RAILWAY
Calpe.nl | + 31 (0)342 - 45 15 44 | Barneveld